



LOWER VALLEY FIRE PROTECTION DISTRICT

Posting of Occupant Load Sign(s)

An approved sign shall be posted in a conspicuous place, between 7-8 feet above the floor, near the main entrance or other location approved by the Fire District.

The occupant load sign(s) shall read as follows:

“MAXIMUM OCCUPANT LOAD is limited to _____ persons. By order of the Fire Chief. “

Where a room can be enlarged by opening a movable partition the sign(s) shall read

“MAXIMUM OCCUPANT LOAD is limited to _____ persons or _____ when partition is in the open position. By order of the Fire Chief”

The sign(s) shall be of permanent material (such as plastic plate) with engraved **white letters and numbers 1 inch high on a red background.**

On new construction architect drawings must show the occupant load calculations. On existing occupancies the LVFD will calculate or verify the maximum load. Ref: IFC 1004.3

Revised 2/25/2015