



Fire Hydrants

Fire Hydrants. Fire hydrant pumper connections shall be equipped with a five inch non threaded sexless connection (commonly referred to as Storz) and metal cap and can be opened by a standard pentagon nut hydrant wrench.

Adapters are not acceptable on new hydrants.

The two- and one-half inch butts shall be furnished with National Standard Thread. Pumper connections shall face the street unless directed otherwise by the Fire Chief.

The number of and fire hydrant locations (spacing) shall be as determined by LVFD in accordance with the International Fire Code-latest adopted edition as amended.

As a minimum a fire hydrant shall be installed at each street intersection.

Revised 1/10/19